

+	Product	Company	Category	Listing Country	Cert #
—	Pipe Fittings	Vantec Industrial	Pipe Fittings	United Kingdom	
	Class of Work 1920 - Coupling & Fitting, All Type		Approval Standard FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems	Certification Type FM Approved	
—	Model VAT02	Vantec Industrial	Grooved Couplings, Standard-Flexible	United Kingdom	
	Class of Work 1920 - Coupling & Fitting, All Type		Approval Standard FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems	Certification Type FM Approved	
—	Model VAT13	Vantec Industrial	Grooved Split Flanges, Flexible	United Kingdom	
	Class of Work 1920 - Coupling & Fitting, All Type		Approval Standard FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems	Certification Type FM Approved	
—	Models VAT09, VAT09S, VAT09U	Vantec Industrial	Pipe Fittings, Side Outlet, Rigid	United Kingdom	
	Class of Work 1920 - Coupling & Fitting, All Type		Approval Standard FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems	Certification Type FM Approved	
—	Model VAT2X	Vantec Industrial	Grooved Couplings, Reducing-Flexible	United Kingdom	
	Class of Work 1920 - Coupling & Fitting, All Type		Approval Standard FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems	Certification Type FM Approved	
—	Model VAT01	Vantec Industrial	Grooved Couplings, Standard-Rigid	United Kingdom	
	Class of Work 1920 - Coupling & Fitting, All Type		Approval Standard FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems	Certification Type FM Approved	
—	Model VAT1X	Vantec Industrial	Grooved Couplings, Standard-Rigid	United Kingdom	
	Class of Work 1920 - Coupling & Fitting, All Type		Approval Standard FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems	Certification Type FM Approved	

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm



Pipe Fittings

Product Description

Model No	Description	Nominal Pipe Size, mm	Rated Working Pressure		Remarks
			psi	(kPa)	
VAT03	90° Elbow	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT04	45° Elbow	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT15	22.5 degree Elbow	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT16	11.25 degree Elbow	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT06	End Cap	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT10	Equal Cross	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT05	Equal Tee	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT08	Flange Adapter	33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141, 159, 165, 168, 219, 273, 325	300	(2065)	a, b
VAT11	Concentric Reducer Grooved	42 x 33 48 x 33, 42 60 x 33, 42, 48 73 x 33, 42, 48, 60 76 x 33, 42, 48, 60 89 x 33, 42, 48, 60, 73, 76 108 x 33, 42, 48, 60, 73, 76, 89 114 x 33, 42, 48, 60, 73, 76, 89 133 x 33, 42, 48, 60, 73, 76, 89, 108, 114 140 x 33, 42, 48, 60, 73, 76, 89, 108, 114 141 x 33, 42, 48, 60, 73, 76, 89, 108, 114 159 x 33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141 165 x 33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 141 168 x 33, 42, 48, 60, 73, 76, 89, 108, 114, 133, 140, 141 219 x 60, 73, 76, 89, 108, 114, 140, 141, 159, 165, 168 273 x 60, 73, 76, 89, 108, 114, 140, 141, 159, 165, 168, 219 325 x 108, 114, 140, 141, 159, 165, 168, 219, 273	300	(2065)	a, b

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Model No	Description	Nominal Pipe Size, mm	Rated Working Pressure		Remarks
			psi	(kPa)	
VAT07	Reducing Tee Grooved	42 x 33 48 x 33, 42 60 x 33, 42, 48 73 x 33, 42, 48, 60 76 x 33, 42, 48, 60 89 x 33, 42, 48, 60, 73, 76 108 x 33, 42, 48, 60, 76, 89 114 x 33, 42, 48, 60, 73, 76, 89 133 x 33, 42, 48, 60, 76, 89, 114 140 x 33, 42, 48, 60, 73, 76, 89, 114 141 x 33, 42, 48, 60, 73, 76, 89, 114 159 x 33, 42, 48, 60, 76, 89, 108, 114 165 x 33, 42, 48, 60, 73, 76, 89, 114 168 x 33, 42, 48, 60, 73, 76, 89, 114 219 x 33, 42, 48, 60, 73, 76, 89 273 x 60, 76, 89, 114 325 x 60, 76, 89, 114	300	(2065)	a, b
VAT07S	Reducing Tee Threaded	42 x 33 48 x 33, 42 60 x 33, 42, 48 73 x 33, 42, 48, 60 76 x 33, 42, 48, 60 89 x 33, 42, 48, 60, 73, 76 108 x 33, 42, 48, 60, 76, 89 114 x 33, 42, 48, 60, 73, 76, 89 133 x 33, 42, 48, 60, 76, 89, 114 140 x 33, 42, 48, 60, 73, 76, 89, 114 141 x 33, 42, 48, 60, 73, 76, 89, 114 159 x 33, 42, 48, 60, 76, 89, 108, 114 165 x 33, 42, 48, 60, 73, 76, 89, 114 168 x 33, 42, 48, 60, 73, 76, 89, 114 219 x 33, 42, 48, 60, 73, 76, 89 273 x 60, 76, 89, 114 325 x 60, 76, 89, 114	300	(2065)	a, b

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Model No	Description	Nominal Pipe Size, mm	Rated Working Pressure		Remarks
			psi	(kPa)	
VAT11S	Concentric Reducer Threaded	42 x 33 48 x 33, 42 60 x 33, 42, 48 73 x 33, 42, 48, 60 76 x 33, 42, 48, 60 89 x 33, 42, 48, 60, 73, 76 108 x 33, 42, 48, 60, 76, 89 114 x 33, 42, 48, 60, 73, 76, 89 133 x 33, 42, 48, 60, 76, 89, 114 140 x 33, 42, 48, 60, 73, 76, 89 141 x 33, 42, 48, 60, 73, 76, 89, 114 159 x 33, 42, 48, 60, 73, 76, 89, 108, 114 165 x 33, 42, 48, 60, 73, 76, 89, 114 168 x 33, 42, 48, 60, 73, 76, 89, 114 219 x 33, 42, 48, 60, 73, 76, 89, 114 273 x 60, 76, 89, 114 325 x 60, 76, 89, 114	300	(2065)	a, b
VAT12	Grooved Reducing Cross	73 x 60 76 x 60 89 x 33, 42, 48, 60, 76 114 x 33, 42, 48, 60, 76, 89 140 x 33, 42, 48, 60, 76, 89, 114 141 x 60, 73, 76, 89, 114 165 x 33, 42, 48, 60, 76, 89, 114 168 x 60, 73, 76, 89, 114, 140, 141 219 x 114, 140, 141, 165, 168 273 x 165, 168, 219 325 x 165, 168, 219, 273	300	(2065)	a, b
VAT08S	Blind Flange	60, 76, 89, 114	300	(2065)	a, b, d

Remarks:

- a. Ductile Iron
- b. Approved when provided with a painted coating.
- c. Available with NPT Threads according to ANSO B1.20.1 specifications
- d. Available with Class 150 flanges

Details

Company

Vantec Industrial
128 City Road, London, EC1V
2NX, United Kingdom

Category	Pipe Fittings
Class of Work	1920 - Coupling & Fitting, All Type

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm



Approvals

Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Grooved Couplings, Standard-Flexible

Model VAT02

Product Description

	Model VAT02 ^a															
	Nominal Pipe Size															
Pipe Description	1 (33.4)	1-1/4 (42.2)	1-1/2 (48.3)	(57.0)	2 (60.3)	2-1/2 (73.0)	(76.1)	3 (88.9)	(108.0)	4 (114.3)	(133.0)	(139.7)	5 (141.3)	(159.0)	(165.1)	6 (168.3)
Schedule 40, Cut Groove	300 (2070)	300 (2070)	300 (2070)		300 (2070)		300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)		300 (2070)	300 (2070)	300 (2070)
Schedule 40, Roll Groove	300 (2070)	300 (2070)	300 (2070)		300 (2070)		300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)		300 (2070)	300 (2070)	300 (2070)
Schedule 30, Cut Groove																
Schedule 30, Rolled Groove	300 (2070)	300 (2070)	300 (2070)		300 (2070)		300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)		300 (2070)	300 (2070)	300 (2070)
ThinWall Pipes																
Schedule 10, Rolled Groove	300 (2070)	300 (2070)	300 (2070)		300 (2070)		300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)		300 (2070)	300 (2070)	300 (2070)
Lightwall Pipes																
Schedule 5 Pipe																
Chinese Standard GB/T 3091-2008	300 (2070)	300 (2070)	300 (2070)		300 (2070)		300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)		300 (2070)	300 (2070)	300 (2070)

Remark:
a. Approved for use with EPDM gasket.

Details

Cookies help us improve your website experience.

By using our website, you agree to our use of cookies.

CategoryGrooved Couplings, Standard-Flexible

Confirm

 Approvals

Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Grooved Split Flanges, Flexible

Model VAT13

Product Description

Model No	Nominal Pipe Size, in	Rated Working Pressure		Bolt Pattern	Remarks
		psi	(kPa)		
VAT13	2, 2-1/2, 3, 4, 5, 6, 8	300	(2065)	ANSI 125	a, b, c, d
VAT13	76.1, 108, 133, 139.7, 159, 165.1 mm	300	(2065)	ANSI 125	a, b, c, d

Remarks:

- a. Min schedule cut groove pipe to be joined: 6 in. or smaller - Schedule 40; 8 in. or larger - Schedule 30
- b. Min schedule rolled groove pipe to be joined: 6 in. or smaller - Schedule 10; 8 or 10 in. - 0.188 in. (5 mm) wall; 12 in. 0.250 in. (6.35 mm) wall
- c. With EPDM gasket
- d. Available with a Red, Orange, Silver, Green or Grey Epoxy Coating

Details

Category	Grooved Split Flanges, Flexible
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Vantec Industrial
128 City Road, London, EC1V 2NX, United Kingdom

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Models VAT09, VAT09S, VAT09U

Product Description

Model No	Description	Nominal Pipe Size, mm	Rated Working Pressure		Remarks
			psi	(kPa)	
VAT09	Mechanical Tee (Grooved Outlet)	60 x 33, 42, 48 76 x 33, 42, 48 89 x 33, 42, 48, 60 114 x 33, 42, 48, 60, 76, 89 140 x 33, 42, 48, 60, 76, 89 141 x 73, 76, 89 165 x 33, 42, 48, 60, 76, 89, 114 168 x 33, 42, 48, 60, 76, 89, 114 219 x 33, 42, 48, 60, 73, 76, 89, 114	300	(2065)	a, b, c, e
VAT09S	Mechanical Tee (Threaded Outlet)	42 x 21, 26 48 x 21, 26, 33 60 x 21, 26, 33, 42, 48	300	(2065)	a, b, c, d, e, f, h, j
VAT09S	Mechanical Tee (Threaded Outlet)	73 x 21, 26, 33, 42, 48, 60 76 x 21, 26, 33, 42, 48 89 x 21, 26, 42, 48, 60 108 x 42, 48, 60, 76, 89 114 x 21, 26, 42, 48, 60, 73, 76, 89 133 x 42, 48, 60, 76, 89 140 x 21, 26, 42, 48, 60, 73, 76, 89 141 x 21, 26, 33, 42, 48, 60, 73, 76, 89 165 x 21, 26, 42, 48, 60, 73, 76, 89 168 x 21, 26, 33, 42, 48, 60, 73, 76, 89, 114 219 x 33, 42, 48, 60, 73, 76, 89, 114	300	(2065)	a, b, c, d, e, g, i, j
VAT09U	U-Bolt Mechanical Tee (Threaded Outlet)	33 x 21 42 x 21, 26 48 x 21, 26, 33 60 x 21, 26, 33	300	(2065)	a, b, c, d, e, f, h, j
VAT09U	U-Bolt Mechanical Tee (Threaded Outlet)	33 x 26	300	(2065)	a, b, c, d, e, k
VAT09U	U-Bolt Mechanical Tee (Threaded Outlet)	73 x 21, 26, 33 76 x 21, 26, 33 89 x 21, 26, 33	300	(2065)	a, b, c, d, e, g, i, j

Remarks:

- a. Min schedule cut groove pipe to be joined: 6 in. or smaller - Schedule 40; 8 in. or larger - Schedule 30.
- b. Min schedule rolled groove pipe to be joined: 6 in. or smaller - Schedule 10; 8 in. or larger - 0.188 in. (5 mm) wall.
- c. With EPDM gasket
- d. Available with NPT Threads according to ANSI B1.20.1 specifications
- e. Available with a Red, Orange, Silver, Green or Gray Epoxy Coating
- f. All products with a 33.7 mm outlet are FM Approved for use with sprinklers K25.2 and smaller.
- g. All products with a 33.7 mm outlet are FM Approved for use with sprinklers K29.4 and smaller.
- h. All products with a 21.9 mm outlet are FM Approved for use with sprinklers K8.0 and smaller.

Confirm

- i. All products with a 21.9 mm outlet are FM Approved for use with sprinklers K11.7 and smaller.
- j. All products with a 26.9 mm outlet are FM Approved for use with sprinklers K17.6 and smaller.
- k. All products with a 26.9 mm outlet are FM Approved for use with sprinklers K11.7 and smaller.

Details

Category	Pipe Fittings, Side Outlet, Rigid
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Vantec Industrial
128 City Road, London, EC1V 2NX, United Kingdom

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Grooved Couplings, Reducing-Flexible

Model VAT2X

Product Description

Model No	End Connection	Nominal Pipe Size, in	Rated Working Pressure		Remarks
			psi	(kPa)	
VAT2X	Rolled Groove, Cut Groove	2 x 1 1/4, 1-1/2 2-1/2 x 1, 1-1/4, 1-1/2 76.1 mm x 1-1/2, 2 3 x 1-1/2, 2,2-1/2, 76.1 mm 4 x 1-1/2, 2,2-1/2, 76.1 mm, 3 5 x 4 6 x 2-1/2, 3,4 8 x 6	300	(2065)	a, b, d, e
VAT2X	Rolled Groove	2 x 1 1/4, 1-1/2 2-1/2 x 1, 1-1/4, 1-1/2 76.1 mm x 1-1/2, 2 3 x 1-1/2, 2, 2-1/2, 76.1 mm 4 x 1-1/2, 2, 2-1/2, 76.1 mm, 3 5 x 4 6 x 2-1/2, 3, 4 8 x 6	300	(2065)	c, d, e

- Remarks:
- a. Min schedule cut groove pipe to be joined: 6 in. or smaller - Schedule 40; 8 in. or larger - Schedule 30
 - b. Min schedule rolled groove pipe to be joined: 6 in. or smaller - Schedule 40; 8 in. or larger - Schedule 30
 - c. Min schedule rolled groove pipe to be joined: 6 in. or smaller - Schedule 10; 8, 10 or 12 in. - 0.188 in. (5 mm) wall
 - d. With EPDM gasket
 - e. Available with a Red, Orange, Silver, Green or Grey Epoxy Coating

Details

Company

Category	Grooved Couplings, Reducing-Flexible
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Pipe Protection Systems
Certification Type	Confirm FM Approved

Vantec Industrial
128 City Road, London, EC1V
2NX, United Kingdom

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

FM Approvals

Listing Country United Kingdom

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Grooved Couplings, Standard-Rigid

Model VAT01

Product Description

Pipe Description	Rated Working Pressures for Model VAT01 Rigid Coupling by Pipe ^{a, b, c, d}															
	Nominal Pipe Size															
Pipe Description	1 (33.4)	1-1/4 (42.7)	1-1/2 (48.3)	(57.0)	2 (60.3)	2-1/2 (73.1)	(76.1)	3 (88.9)	(108.0)	4 (114.3)	(133.0)	(139.7)	5 (141.3)	(159.0)	(165.1)	6 (168.3)
Schedule 40, Cut Groove	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)
Schedule 40, Roll Groove	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)
Schedule 30, Cut Groove																
Schedule 30, Rolled Groove	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)
ThinWall Pipes																
Schedule 10, Rolled Groove	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)	300 (2070)
0.188" Wall, Rolled Groove																
Lightwall Pipes, Rolled Groove																
Schedule 5 Pipe																

Remarks:

a.) Minimum schedule cut groove pipe to be joined: 6 inch or smaller, Schedule 40; 8 inch or larger, Schedule 30

b.) Minimum schedule rolled groove pipe to be joined: 6 inch or smaller, Schedule 10; 8, 10 or 12 inch - 0.188 inch (5 mm) wall

c.) All couplings in table above, Approved when supplied with an EDPM gasket using standard gasket lubricant

d.) Available with a Red, Orange, Silver, Green or Grey Epoxy Coating

Details

Category

Grooved Couplings, Standard-Rigid

Class of Work

1920 - Coupling & Fitting, All Type

Confirm

FM Approvals

Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Model VAT1X

Product Description

Pipe Description	Rated Working Pressures for Model VAT1X Rigid Coupling by Pipe ^{a, b, c, d}																
	Nominal Pipe Size																
	1 (33.7)	1-1/4 (42.7)	1-1/2 (48.3)	(57)	2 (60.3)	2-1/2 (73.1)	(76.1)	3 (88.9)	(108)	4 (114.3)	(133)	(139.7)	5 (141.3)	(159)	(165.1)	6 (168.3)	(200)
Schedule 40, Cut Groove	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)
Schedule 40, Roll Groove	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)
Schedule 30, Cut Groove																	
Schedule 30, Rolled Groove	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)
Thinwall Pipes, Rolled Groove																	
Schedule 10, Rolled Groove	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)	300 (2065)
0.188" Wall, Rolled Groove																	
Lightwall Pipes, Rolled Groove																	
Schedule 5 Pipe, Rolled Groove																	

Remarks:

a.) Minimum schedule cut groove pipe to be joined: 6 inch or smaller. Schedule 40: 8 inch or larger, Schedule 30

b.) Minimum schedule rolled groove pipe to be joined: 6 inch or smaller. Schedule 10: 8, 10 or 12 inch - 0.188 inch (5 mm) wall

c.) All couplings in table above, Approved when supplied with an EDPM gasket using standard gasket lubricant

d.) Available with a Red, Orange, Silver, Green or Grey Epoxy Coating

Confirm

Details

Category	Grooved Couplings, Standard-Rigid
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Com

Vantec Ir
128 City f

Cookies help us improve your website experience.
By using our website, you agree to our use of cookies.

Confirm

Fittings, Grooved and Plain End

COMPANY

VANTEC INDUSTRIAL LTD

128 City Road

London, EC1V 2NX United Kingdom

EX29446

View model for additional information

Grooved fitting, Model(s): [VAT012](#), [VAT015](#), [VAT016](#), [VAT03](#), [VAT04](#), [VAT05](#), [VAT06](#), [VAT07](#), [VAT07S](#), [VAT08](#), [VAT08S](#), [VAT10](#), [VAT11](#), [VAT11S](#)

Last Updated on 2024-09-16

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."

Cookies on UL Solutions

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. [Learn more](#)

[Cookies Settings](#)[Reject All](#)[Accept All Cookies](#)

Fittings, Rubber Gasketed

COMPANY

VANTEC INDUSTRIAL LTD

128 City Road

London, EC1V 2NX United Kingdom

EX29447

View model for additional information

Coupling, Model(s): [VAT01](#), [VAT1X](#), [VAT2X](#)

Flange adapter, Model(s): [VAT13](#)

Flexible coupling, Model(s): [VAT02](#)

Side outlet, Model(s): [VAT09](#), [VAT09S](#), [VAT09U](#)

Last Updated on 2024-09-16

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."

Cookies on UL Solutions

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. [Learn more](#)

[Cookies Settings](#)[Reject All](#)[Accept All Cookies](#)